

Zeitschrift: IABSE structures = Constructions AIPC = IVBH Bauwerke
Band: 13 (1989)
Heft: C-49: Structures in sanitary engineering

Artikel: Egg-shaped prestressed concrete digester tanks, Yokohama (Japan)
Autor: Nojiri, Y.
DOI: <https://doi.org/10.5169/seals-21565>

Nutzungsbedingungen

Die ETH-Bibliothek ist die Anbieterin der digitalisierten Zeitschriften auf E-Periodica. Sie besitzt keine Urheberrechte an den Zeitschriften und ist nicht verantwortlich für deren Inhalte. Die Rechte liegen in der Regel bei den Herausgebern beziehungsweise den externen Rechteinhabern. Das Veröffentlichen von Bildern in Print- und Online-Publikationen sowie auf Social Media-Kanälen oder Webseiten ist nur mit vorheriger Genehmigung der Rechteinhaber erlaubt. [Mehr erfahren](#)

Conditions d'utilisation

L'ETH Library est le fournisseur des revues numérisées. Elle ne détient aucun droit d'auteur sur les revues et n'est pas responsable de leur contenu. En règle générale, les droits sont détenus par les éditeurs ou les détenteurs de droits externes. La reproduction d'images dans des publications imprimées ou en ligne ainsi que sur des canaux de médias sociaux ou des sites web n'est autorisée qu'avec l'accord préalable des détenteurs des droits. [En savoir plus](#)

Terms of use

The ETH Library is the provider of the digitised journals. It does not own any copyrights to the journals and is not responsible for their content. The rights usually lie with the publishers or the external rights holders. Publishing images in print and online publications, as well as on social media channels or websites, is only permitted with the prior consent of the rights holders. [Find out more](#)

Download PDF: 13.03.2026

ETH-Bibliothek Zürich, E-Periodica, <https://www.e-periodica.ch>



5. Egg-Shaped Prestressed Concrete Digester Tanks, Yokohama (Japan)

Owner:	Sewage Works Bureau of Yokohama City
Construction designer:	Nippon Jogesuido Sekkei Co. Ltd.
Contractor:	Kajima Corporation
Works' duration:	40 months
Commissioning year:	1987
Capacity:	6800 m³ × 12 units
Dimensions:	
maximum diameter:	22.7 m
height:	33.6 m
Material quantities per unit:	
concrete:	1350 m³
reinforcement:	100 t
prestressing tendon:	66 t
liner:	1900 m²

Introduction

In Yokohama, the second largest city in Japan, the amount of sewage treatment has rapidly increased due to the increase in both population and rate of sewer system usage. This led to more than 14 million tons of sludge per year being produced in the sewage treatment process, making it necessary for the sludge treatment facilities to be expanded. In view of this situation, 12 units of digester tanks of egg-shaped prestressed concrete, the first of this type in Japan, have been constructed by the Sewage Works Bureau of Yokohama City.

Design

After due consideration of the loose soil condition on the site, a ring-shaped foundation supported by piles was applied (Fig. 1). This was also to ensure the stability of the tanks during earthquakes.

Due to the lower stiffness of the soil beneath the tank compared with the piles, no soil reaction in this type of foundation is expected. Thus tensile stress occurs even in lower part of the shell caused by the liquid load of sludge. To counteract this, a prestress was introduced in both circumferential and meridian directions with helically positioned tendons since the underground anchorage of circumferential tendon outside the shell was not available (Fig. 2).

The structural analyses were carried out using the axisymmetric finite element method for the dead loads and an asymmetric one for seismic loads. In addition to the static analyses, dynamic analyses were carried out to estimate the distribution of the hydrodynamic pressure by means of the finite element method in which the interaction of the tank, liquid and the surrounding soil was taken into consideration. Observations of ambient vibration were carried out on the completed tank. Predominant frequencies approximately agreed with the analysis.




Fig. 1 Section




Fig. 2 Helically positioned tendons

Construction

The concrete shell of 350-500 mm in thickness was constructed by 1.5 m lift by the Dywidag jump form method (Fig. 3).

Concrete shell is required to provide high water- and air-tightnesses. To secure these requirements the following methods were employed:

- 1) a concrete of mix proportion with low water cement ratio as well as low cement content was used
- 2) after careful case study, the optimum order of concrete placing was determined
- 3) moderate prestressing was applied

By combining the above methods it was expected to control the thermal cracking due to heat of hydration. During the construction a few crackings occurred, which were repaired by means of epoxy injection

- 4) a concrete joint treatment with set retarding agent and water jetting was used to provide good bonding of construction joints.

The water filling and air pressure tests carried out after completion of tanks proved that the water- and air-tightnesses were satisfactory.

Another requirement was the durability of the concrete shell against the chemical action of sludge and digestion gas that might cause deterioration and neutralization of the concrete as well as corrosion of reinforcing steel. To achieve greater durability than by concrete alone, a 350




Fig. 3 Construction by jump form method

micron lining of tar-epoxy resin was applied to the entire inner surface. A higher degree of durability was required of the surface in contact with the digestion gas, so the tar-epoxy liner of this part was reinforced with glass cloth.

Since starting the operation in April, 1987, these 12 units of tanks have ably proved their digestion efficiency. It is also expected that they will display an excellent long term durability and earthquake resistance.

(Y. Nojiri)




Fig. 4 Prestressed concrete digester tanks