**Zeitschrift:** IABSE reports = Rapports AIPC = IVBH Berichte

**Band:** 73/1/73/2 (1995)

**Artikel:** Evaluation and analysis of a masonry structure for seismic loading

Autor: Mosur, T.V. / Muruganandan, Murugs

**DOI:** https://doi.org/10.5169/seals-55178

## Nutzungsbedingungen

Die ETH-Bibliothek ist die Anbieterin der digitalisierten Zeitschriften auf E-Periodica. Sie besitzt keine Urheberrechte an den Zeitschriften und ist nicht verantwortlich für deren Inhalte. Die Rechte liegen in der Regel bei den Herausgebern beziehungsweise den externen Rechteinhabern. Das Veröffentlichen von Bildern in Print- und Online-Publikationen sowie auf Social Media-Kanälen oder Webseiten ist nur mit vorheriger Genehmigung der Rechteinhaber erlaubt. Mehr erfahren

### **Conditions d'utilisation**

L'ETH Library est le fournisseur des revues numérisées. Elle ne détient aucun droit d'auteur sur les revues et n'est pas responsable de leur contenu. En règle générale, les droits sont détenus par les éditeurs ou les détenteurs de droits externes. La reproduction d'images dans des publications imprimées ou en ligne ainsi que sur des canaux de médias sociaux ou des sites web n'est autorisée qu'avec l'accord préalable des détenteurs des droits. En savoir plus

#### Terms of use

The ETH Library is the provider of the digitised journals. It does not own any copyrights to the journals and is not responsible for their content. The rights usually lie with the publishers or the external rights holders. Publishing images in print and online publications, as well as on social media channels or websites, is only permitted with the prior consent of the rights holders. Find out more

**Download PDF:** 09.12.2025

ETH-Bibliothek Zürich, E-Periodica, https://www.e-periodica.ch



# Evaluation and Analysis of a Masonry Structure for Seismic Loading

Evaluation et calcul d'une structure en maçonnerie sous charge sismique Untersuchung und Berechnung eines Mauerwerkbaus unter Erdbebenbelastung

T.V. MOSUR
Senior Associate
Totten Sims Hubicki Associates
Whitby, ON, Canada



T.V. Mosur has been a specialist in structural investigations for over 30 years. Prior to joining TSH, he was involved in teaching and consulting engineering work in international projects. At TSH he is Chief Structural Engineer. He is a member of several technical associations.

# Murugs MURUGANANDAN Senior Structural Engineer Management Board Secretariat Toronto, ON, Canada



Murugs Muruganandan obtained his civil engineering degree in 1968 from Univ. of Ceylon, Sri Lanka. He worked on several structural enginering projects in Sri Lanka, Nigeria and Canada. At present he is with the Management Board Secretariat of the government of Ontario.

#### SUMMARY

Several steps must be taken to restore or rehabilitate an existing structure for various imposed load conditions. A history and condition survey of an existing structure revealed an inadequate resistance to seismic forces. Field testing and inspection revealed deficiencies in the original construction which required conformance to current Building Code. A structural analysis was carried out to determine the structural adequacy of the masonry walls and to facilitate rehabilitation in an economical way. This paper deals with the evaluation of existing clay tile block masonry work for retrofitting the structure.

# RÉSUMÉ

Pour divers cas de charges, il faut effectuer plusieurs démarches afin d'assurer la réparation et la consolidation d'une structure existante. L'étude d'un ouvrage a montré une résistance parasismique inadéquate. Les vérifications sur le site ont mis en évidence les défaillances dans la construction initiale, la rendant non conforme aux exigences actuelles des normes. Les auteurs ont déterminé à l'aide d'un calcul statique la résistance du mur en maçonnerie, ainsi que les possibilités économiques du renforcement à envisager.

#### ZUSAMMENFASSUNG

Um ein Tragwerk gegenüber unterschiedlichen Belastungszuständen wieder auf eine genügende Tragfähigkeit zu bringen, müssen mehrere Schritte unternommen werden. Am Beispiel eines Tragwerks mit mangelhaftem Erdbebenwiderstand wurde zuerst die Vorgeschichte und der gegenwärtige Zustand aufgenommen. Untersuchungen und Inspektionen enthüllten Mängel in der ursprünglichen Konstruktion und der Erfüllung der heutigen Normanforderungen. Mittels einer statischen Berechnung wurde die Tragfähigkeit der Mauerwerkswand und deren wirtschaftliche Sanierungsmöglichkeiten bestimmt.



#### INTRODUCTION

Rehabilitation of existing buildings has grown significantly in the construction industry during the current recession. Retrofitting of structures must comply with current building regulations and have structural adequacy to resist such imposed loading as earthquakes.

The building under study was initially constructed in 1969 with a hollow tile clay block construction.

Although structural clay tile was first produced in the United States of America in about 1875, archaeological excavations have proved that structures were built with clay burnt bricks as long as 5000 years ago. In 1921 ASTM proposed a standard for hollow clay tiles. Subsequently, the use of hollow clay tile block buildings was predominant between 1940 and 1960.

The building is a clay tile block, cavity wall single storey structure with structural steel open web steel joists supporting the metal deck roofing. The structure is located in Ottawa, Canada, which is a seismic zone. Since its construction, several changes have occurred in the Canadian Building Codes (in the last 20 years).

During the construction of an addition to the building in 1992, it was discovered that several cracks had developed at beam bearing locations at the load bearing walls of the original building. During the renovation, it was found that the existing clay tile blocks were not adequately reinforced or grouted and were defective in their original construction. Although there were no major visual deficiencies noted on the outside, it was decided to review the rest of the original building for its structural adequacy to resist gravity and seismic loads according to current code requirements.

#### **OBSERVATIONS**

The layout of the building is shown on Figure 1. The walls are built with clay tile block and face clay brick as shown on Figure 3. Typical clay tile block used in the building is shown in Figure 2.

Inspection and investigation of the building revealed that there are several areas of deficient construction and inadequacies in the reinforcement of the original clay tile block masonry walls. The normal method to repair and restore the clay tile block walls would be to grout, reinforce, and restore the walls to the original design details conforming to current code requirements. The cost of such repairs would be substantial and the restoration would cause disruption to the operation of the building. Since the structure did not exhibit severe distress, it was decided to carry out a detailed structural analysis to establish the level of stresses in clay tile block masonry walls.

#### **PURPOSE OF ANALYSIS**

The purpose of this analysis was to determine if the unreinforced masonry walls were able to resist combined gravity and wind or earthquake loads in accordance with the Building Code. The current Building Code requires that load bearing and lateral load resisting masonry walls in velocity or acceleration related seismic zones of 2 and higher shall be reinforced. The Ottawa area is in an acceleration related zone of 4 and a velocity related zone of 2.






Fig. 1 Building Layout






Fig. 2 Clay Tile Block

Fig. 3 Wall Sections

#### **ANALYSIS MODEL**

The wall system which resist gravity and earthquake loads is shown on Figure 1. The load resisting system consists of 45 individual walls. The exterior masonry cavity walls have been assumed to act integrally in resisting lateral forces. The clay tile block wall and brick wall are tied together with ladder type reinforcement. Gravity loads, however are supported by the loaded wythe of clay tile block masonry only.

The analysis is based on a relative wall stiffness method. Torsional effects due to horizontal forces are adequately dealt with by a stiffness matrix of the composite walls at various locations, as shown on Figure 1. Calculations indicated that seismic force controlled the analysis.

The horizontal component of earthquake load at the base of the structure V<sub>e</sub> is determined from the following equation:

$$V_{\bullet} = V \cdot S \cdot I \cdot F \cdot W \cdot as per O.B.C. 4.1.9.1 (5) ..... [10]$$

Working stress design is considered in the evaluation of stresses to be compatible with the age of construction.

The total horizontal seismic forces along the building are distributed to walls based on their relative stiffness.

The design lateral earthquake force at the base of structure V = 1,190 kN. The design eccentricities are computed to obtain torsional moments in the orthogonal direction. The horizontal force in the walls ( $H_{TI}$  caused by the torsional moments ( $M_{txI}$  is determined by the following equation:

$$H_{\tau} = [K \cdot d^2/\Sigma (K \cdot d^2)] \cdot M_{tv}/d \dots$$
 [8]

where d is the distance from the centre of gravity of the wall to the centre of rigidity of the structure.



The axial, flexural and shear stresses are computed. The critical stresses at various walls are shown in Table 1. The calculated stresses are compared with allowable stresses noted in Table 2 and the overstress at various wall locations are established.

	CALCULATED STRESSES							
WALL NO.	MAX. AXIAL STRESS (MPa)	MIN. AXIAL STRESS (MPa)	COMP. STRESS ALLOW. STRESS	TENSILE STRESS ALLOW, STRESS	SHEAR STRESS (MPa)	SHEAR STRESS ALLOW. STRESS		
14	0.311	-0.041	0.758	0.292	0.068	0.486		
16	0.262	-0.076	0.640	. 0.541	0.117	0.834		
18	0.343	-0.029	0.837	0.208	0.045	0.321		
22	0.409	0.005	0.997		0.040	0.287		
25	0.380	-0.105	0.927	0.751	0.131	0.938		
26	0.311	-0.046	0.758	0.326	0.014	0.099		
27	0.385	-0.068	0.940	0.484	0.102	0.729		
28	0.374	-0.097	0.912	0.695	0.085	0.610		
29	0.343	-0.094	0.837	0.672	0.084	0.599		
30	0.452	0.065	1.103	<b>=</b>	0.012	0.084		
32	0.308	-0.138	0.752	0.986	0.118	0.845		
33	0.304	-0.140	0.741	1.000	0.119	0.850		
34	0.295	-0.142	0.719	1.016	0.100	0.717		
38	0.292	-0.137	0.713	0.977	0.047	0.332		
40	0.351	-0.069	0.857	0.490	0.064	0.458		
45	0.316	-0.089	0.770	0.635	0.016	0.114		
47	0.438	-0.131	1.068	0.935	0.118	0.840		

Notes:

Allowable Shear Stress = 0.14 MPa (15psi x 1.333 = 20psi, see Table 2 below)
Allowable Compressive Stress = 0.41 MPa (60psi)
Allowable Tensile Stress = 0.14 MPa (15psi x 1.333 = 20psi, see Table 2 below)
1 MPa = 145.04 psi

TABLE 1

o se sentration and services	ALLOWABLE	STRESSES	S IN UNIT	MASONRY	
CONSTRUCTION	ALLOWABLE COMPRESSIVE STRESSES (psi)			ALLOWABLE STRESSES IN SHEAR OR TENSION IN FLEXURE (psi)	
	MORTAR			MORTAR	
	TYPE M	TYPE S	TYPE N	TYPE M OR S	TYPE N
Cavity walls, solid and hollow units	70 (1)	60 (1)	<sub>55</sub> (1)	15 <sup>(2)</sup>	10 (2)
	(1) On gross cross—sectional area of wall minus area of cavity between wythes. The allowable compressive stresses for cavity walls are based upon the assumption that the floor loads bear upon but one of the two wythes. When hollow walls are loaded concentrically, the allowable stresses may be increased by 25 per cent.			either acting alone or when	

Note: Information shown in Table 2 was obtained from 'Brick and Tile Engineering' by Harry C. Plummer.

TABLE 2



#### **CONCLUSIONS**

The analysis pinpointed areas of overstress due to earthquake loads. The results of the analysis coincided with the problem areas and overstressed locations in the field. It was also evident that the stress levels were not critical in several locations; hence those areas did not need to be reinforced to match the original structure as detailed.

Only areas overstressed would be repaired and reinforced to withstand code imposed loads by this analysis approach. The method followed by this approach of analysis would save a considerable amount of money (approximately C\$200,000.00), downtime and inconvenience to the operation of the building and clients.

#### REFERENCES

- 1. AMRHEIN J. E., Masonry Design Manual. Masonry Industry Advancement Committee, 1972.
- 2. CAN3-S304-M84, Masonry Design for Buildings. Canadian Standards Association, November 1984.
- CHIEN E., Low Rise Office Building Design Aid. Canadian Institute of Steel Construction, May 1991.
- CUTLER AND MIKLUCHIN, Clay Masonry Manual. The Brick and Tile Institute of Ontario, April 1965.
- DRYSDALE ENGINEERING AND ASSOCIATES LIMITED, Design Guide for Load Bearing Single Storey Concrete Block Buildings. Ontario Concrete Block Association, October 1990.
- 6. JOHNSON F. B., Designing, Engineering, and Constructing with Masonry Products. The International Conference on Masonry Structural Systems, 1969.
- 7. MOSUR T. V., DELPH M., Driver's Examination Centre Masonry Wall Investigation, Inspection and Evaluation Report Volume I. Totten Sims Hubicki Associates, November 1993.
- 8. MOSUR T. V., GILLESPIE R., KISILEWICZ A., Driver's Examination Centre Masonry Wall Investigation, Masonry Wall Analysis Report. Totten Sims Hubicki Associates, January 1994.
- 9. National Building Code of Canada and Supplement, 1990. National Research Council of Canada, 1990.
- 10. Ontario Building Code, 1990. Ministry of Housing, Ontario.
- 11. PLUMMER H.C., Brick and Tile Engineering. Brick Institute of America, November 1962.